

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-001

SAMPLE INFORMATION

Sample Number: 1310102-001

Customer Sample Number:

Location: 1H-10 ANNE M. GODING SCHOOL, 900 F ST NE
Type: Dist.
DC VOC

Collection Date:
10/9/2013

Collection Time:
10:20

Sampler:
BS

Received Date and Time:
10/9/2013 3:24:33 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0199 mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0180 mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0100 mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0013 mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.049 mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-003

SAMPLE INFORMATION

Sample Number: 1310102-003

Customer Sample Number:

Location: 3H-4 BKJV LOWELL SCHOOL, 1640 KALMIA
RD NW

Type: Dist.

DC VOC

Collection Date:
10/9/2013

Collection Time:
13:11

Sampler:
BS

Received Date and Time:
10/9/2013 3:24:33 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0204 mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0181 mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0095 mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0010 mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.049 mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-004

SAMPLE INFORMATION

Sample Number: 1310102-004

Customer Sample Number:

Location: 4H-3 LAFAYETTE ELEM SCHOOL, 5701
BROAD BRANCH ROAD NW Type: Dist.
DC VOC

Collection Date: 10/9/2013 Collection Time: 8:18 Sampler: BS Received Date and Time: 10/9/2013 3:24:33 PM Received By: BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0200 mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0181 mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0094 mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0010 mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.049 mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-005

SAMPLE INFORMATION

Sample Number: 1310102-005

Customer Sample Number:

Location: A1H-8 MY 3 SONS BARBER SHOP, 3125
MLK AVE SE Type: Dist.
DC VOC

Collection Date: 10/9/2013 Collection Time: 12:50 Sampler: BS Received Date and Time: 10/9/2013 3:24:33 PM Received By: BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0196 mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0172 mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0088 mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0011 mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.047 mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-007

SAMPLE INFORMATION

Sample Number: 1310102-007

Customer Sample Number:

Location: L-24 DBPR DEANWOOD RECREATION
CENTER, 1350 49TH ST NE
DC VOC

Type: Dist.

Collection Date:
10/9/2013

Collection Time:
10:57

Sampler:
BS

Received Date and Time:
10/9/2013 3:24:33 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0209 mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0178 mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0091 mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0010 mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.049 mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-008

SAMPLE INFORMATION

Sample Number: 1310102-008

Customer Sample Number:

Location: L-12 BLUE PLAINS WASTEWATER
TRTMT, 5000 OVERLOOK AVE SW Type: Dist.
DC VOC

Collection Date: 10/9/2013 Collection Time: 12:11 Sampler: BS Received Date and Time: 10/9/2013 3:24:33 PM Received By: BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0218 mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0193 mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0106 mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0012 mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.053 mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2013

Report Number: LC-W1310102-010

SAMPLE INFORMATION

Sample Number: 1310102-010

Customer Sample Number:

Location: FIELD BLANK
DC VOC

Type: SP

Collection Date:
10/9/2013

Collection Time:
6:47

Sampler:
BS

Received Date and Time:
10/9/2013 3:24:33 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	10/16/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	ND mg/L	10/16/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	10/16/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	10/16/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	ND mg/L	10/16/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/5/2013

Date